

## Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2021	1/10/21	3	5	60	Squirrel	99.99969%
	1/17/21	1	2	60	Squirrel	
	1/22/21	4	4	30	Squirrel	
February 2021	2/11/21	1	3	60	Tree	99.99989%
March 2021	3/13/21	1	1	10	Squirrel	99.99986%
	3/14/21	2	1	60	Equipment Worn Out	
	3/16/21	3	3	60	Equipment Worn Out	
April 2021	4/08/21	3	140	210	Bird	99.98218%
	4/15/21	2	7	60	Bird	
	4/30/21	1	1	55	Equipment Worn Out	
May 2021	5/02/21	4	5	60	Squirrel	99.99957%
	5/20/21	2	1	30	Equipment Damage	
	5/22/21	1	6	60	Equipment Worn Out	
	5/27/21	3	3	20	Bird	
June 2021	6/01/21	1	3	15	Squirrel	99.99917%
	6/06/21	1	5	50	Squirrel	
	6/10/21	3	10	30	Squirrel	
	6/12/21	2	2	90	Bird	
	6/12/21	1	5	30	Squirrel	
	6/27/21	2	4	115	Equipment Worn out	
July 2021	7/01/21	3	1005	85	Lightning	99.95035%
	7/01/21	3	5	30	Bird	
	7/02/21	3	2	45	Lightning induced flashover	
	7/09/21	1	4	60	Equipment worn out	
	7/09/21	4	1	15	Squirrel	
	7/13/21	3	1	45	Electrical failure	
	7/19/21	4	7	20	Squirrel	
	7/19/21	3	1	20	Bird	